

CITY OF NORTH BATTLEFORD 2025 ANNUAL DRINKING WATER QUALITY REPORT



WTP #1



FEH WTP

Executive Summary

This report provides a summary of the Drinking Water Quality of the water produced by the City of North Battleford and the results of the Distribution System monitoring.

The highlights of 2025 were as follows:

- A total of 270 water distribution system bacteria samples were submitted as part of the routine monitoring of the distribution system. None of the routine bacteria samples tested positive for total coliforms and they were all within the recommended chlorine residual guidelines set by the WSA.
- The online turbidity analyzers for Water Treatment Plant #1 ranged from 0.07 NTU to 0.18 NTU monthly average, meeting the guideline of less than 1.0 NTU for 95% of readings.
- The turbidity for the F.E. Holliday Treatment Plant filters ranged from 0.00 to 0.34 NTU for Filter A, 0.01 to 0.56 NTU for Filter B, 0.01 to 0.18 NTU for Filter C, and 0.01 to 0.43 NTU for Filter D. All Filters were below the NTU guidelines of less than 0.3 NTU for 95% of readings and at no time exceeded the Absolute Maximum of 1.0 NTU.
- Monthly free chlorine readings were above the minimum guideline of 0.2 mg/L entering the distribution system. The monthly readings ranged from 1.18 mg/L to 1.65 mg/L at Water Treatment Plant #1 and 0.50 mg/L to 1.35 mg/L at the F.E Holliday Treatment Plant.
- The highest iron reading recorded was 0.02 mg/L at Water Treatment Plant #1 which was below the aesthetic guidelines of 0.3 mg/L.
- The highest manganese reading recorded was 0.09 mg/L at Water Treatment Plant #1 which is above the aesthetic guidelines of 0.05 mg/L. The average monthly readings were 0.01 mg/L for each month.
- In 2025 the City produced 1.73 million m³ compared to 1.67 million m³ in 2024.

The City of North Battleford water treatment plants provided potable water that met the Water Security Agency guidelines.

CITY OF NORTH BATTLEFORD

DRINKING WATER QUALITY

2025 ANNUAL REPORT

CITY OF NORTH BATTLEFORD

DEPARTMENT OF CITY OPERATIONS

2025

Safe Drinking Water Policy

POLICY STATEMENT

The City of North Battleford Council and Administration are committed to providing the community with good quality and safe drinking water throughout the City distribution system.

KEY INDICATORS

Good and safe drinking water quality will be demonstrated by:

- Water that is free of pathogenic organisms and any harmful concentrations of chemicals or other substances as may be identified in provincial drinking water requirements, guidelines, objectives, or recommendations;
- Water that is adequately disinfected; and
- Water that is aesthetically acceptable.

PRIORITY MEASURES

The following essential measures are undertaken to ensure the provision of good and safe drinking water:

- Protection of Water Sources and Watersheds within the City's Jurisdiction and Influence;
- Quality Control, Quality Assurance and Continuous Improvement Programs;
- Water Treatment, Transmission and Distribution System Maintenance and Renewal;
- Staff Training, Certification and Ongoing Learning;
- Regular and Timely Reporting to City Council; and
- Water Quality Monitoring with Public Accountability for Verifying Quality Results.

Table of Contents

Introduction	1
Background.....	1
Water Treatment Plants.....	1
Distribution System.....	2
Tested Parameters	3
Coliform Bacteria, Total.....	3
Escherichia coli, (E. coli)	3
Chlorine	4
Turbidity.....	4
Iron	4
Manganese.....	4
Additional Testing.....	5
General Chemical	5
Chemical Health	5
Trihalomethanes/Haloacetic Acids	5
Pesticides	5
Organics	5
Cryptosporidium and Giardia.....	6
Microcystin.....	6
Wastewater Discharged to Environment	6
Results.....	7
WTP #1 Summary	7
FEH WTP Summary.....	7
Distribution System Routine and 'Other' Bacteria Sampling.....	8
General Chemical.....	8
Chemical Health	8
Cyanide and Mercury	8
Cryptosporidium and Giardia	8
Pesticides	8
Organics	8
Wastewater Discharged to Environment.....	9
Chlorine Residual	9
Aluminum.....	9
pH	9
Dissolved Oxygen.....	9
Total Suspended Solids (TSS)	9
Acute Lethality	9
Water Production.....	9
Conclusion	10
Acknowledgement	11

APPENDICES

- Appendix A: Map of Sample Zones
- Appendix B: Results Tables
- Appendix C: Water Production Volumes
- Appendix D: Glossary

Introduction

The City of North Battleford Annual Drinking Water Quality Report is designed to provide information to City Council, the public, government organizations, and internal management. Data that is presented in this report is collected from the water treatment plants and distribution system within the City of North Battleford.

Background

The City of North Battleford water supply system is comprised of two water treatment facilities, three reservoirs, one booster station, approximately 120 kilometres of water main, 580 fire hydrants and thousands of valves.

The City of North Battleford services approximately 5,500 residential, commercial, industrial, and institutional properties. 1.73 million m³ of water was produced for the community in 2025.

Water Treatment Plants

The City of North Battleford water treatment Facilities consists of two water treatment plants: Water Treatment Plant #1 (WTP #1) and F.E. Holliday Water Treatment Plant (FEH WTP).

WTP #1 (Figure 1) is currently designated as a Class 2 Water Treatment Facility. The plant draws water from a groundwater well field located in the North Saskatchewan River's valley southwest of the city. The water treatment process at WTP #1 consists of 'Train A' which utilizes four pressure filters and 'Train B' which utilizes two open gravity filters. All six filters use greensand media to aid in the removal of manganese and iron. Chlorine gas is the main pre and post filtration disinfection method used at this plant. A liquid form of chlorine is used in pre-treatment when pre-chlorine residuals drop below an acceptable level during an upset condition. The 'Train B' expansion officially came online in September 2012.

In 2016, four new production wells were installed at WTP #1. The four new production wells began operating in the fall of 2016 after the Husky Energy oil spill which caused the City of North Battleford to shut down operations at FEH WTP. The new production wells increased the production capability of WTP #1 to offset lost production from FEH WTP. With the 2009 WTP #1 expansion project, the maximum treatment capacity of WTP #1 increased from 180 m³/hr to approximately 320 m³/hr, however the well field limits the production capability of this plant.



Figure 1. Water Treatment Plant #1



Figure 2. F.E. Holliday Water Treatment Plant

FEH WTP (Figure 2) is designated as a Class 3 Water Treatment Facility. The plant treats surface water directly from the North Saskatchewan River. Water is drawn from the river, sand is removed, and the water is treated for inorganic and organic constituents. Chlorine gas is used as the primary disinfectant with ultraviolet energy (UV) providing additional disinfection. The production capability of this plant may be affected by the turbidity of the North Saskatchewan River and sand bar formation near the plant intake.

The untreated and treated water is monitored and tested daily at each WTP when operating to ensure that the finished product meets the standards set by the Water Security Agency (WSA). A summary of plant operations for each WTP can be found in the results section of this report.

Distribution System

The City of North Battleford has over 120 km of water mains. Mains are a combination of asbestos concrete, cast iron, PVC, HDPE, copper, and steel. In 2025, there were 6 water main leaks detected and repaired. Work was done on 36 hydrants (2 complete rebuilds, 15 repairs, 9 replacements and 10 thaws).

In 2019, the City of North Battleford installed a number of pressure monitoring devices throughout the distribution system. The pressure monitoring devices aid in optimizing the distribution pressure. The pressure in the City's distribution system must be greater than 20 psi at all times. If any part of the water distribution system pressure drops below 20 psi that part of the distribution system is considered depressurized, and is vulnerable to contamination. If the system is considered depressurized, a drinking water advisory is issued to the affected section of the system while corrective actions are performed.

Water in the distribution system is sampled for the presence of bacteria at 12 routine sampling locations biweekly throughout the City. Each sample is field tested for free and total chlorine and turbidity and a sample is then collected in a 100mL bottle for analysis at an accredited laboratory. The Permit to Operate a Waterworks, set out by WSA, requires three samples to be taken per week for a total of 156 samples per year. In 2025, a total of 270 routine monitoring samples were taken.

'Other' samples are collected when there are new services, complaints about taste or odour, following water main repairs, or after any construction activity where water distribution quality may be affected. In 2025, a total of 89 'other' samples were

submitted. These are not considered 'routine' samples, however, "other" samples are field screened and analyzed for the same testing parameters.

A map of the City's neighborhoods can be found in Appendix A and a summary of 'routine' and 'other' samples referencing the neighborhood location of these samples can be found in Appendix B, Table 3.

Tested Parameters

The City of North Battleford performs testing as required by the Permit to Operate a Waterworks and as directed by WSA. Additional testing may be done voluntarily for quality assurance and in advance of proposed changes to Drinking Water Quality Guidelines to determine the potential changes in the treatment processes. Tested parameters may or may not be subject to a guideline limit. These limits can be health-based, Maximum Acceptable Concentration (MAC), interim Maximum Acceptable Concentration (iMAC), or based on Aesthetic Objectives (AO) such as taste or odor. These limits may be expressed as milligrams per litre (mg/L), micrograms per litre (µg/L), or counts per millilitre or litre (0 cts/100 mL or 0 cts/100 L). Each tested parameter is outlined in greater detail below. The results for these tested parameters can be found in the results section of this report.

Coliform Bacteria, Total

Total coliform bacteria are used as an operational tool to determine the drinking water treatment system effectiveness. Total coliforms include a variety of naturally occurring bacteria in water, soil, and vegetation as well as human and animal feces. The majority of these bacteria are harmless. The presence of total coliform bacteria indicates that the system is vulnerable to contamination and that additional action needs to be taken. Any exceedances should be investigated. Testing is used to ensure water quality meets permitted criteria. The guideline for the presence/absence of Total Coliforms is a health objective, and as such is expressed as a MAC. The WSA limit for total coliform bacteria is 0 cts/100 mL of a sample.

Escherichia coli, (E. coli)

E. coli is a type of coliform bacteria commonly found in the intestines of humans and warm-blooded animals. Most strains of E.coli do not cause illness in healthy humans and are actually beneficial to the synthesis of vitamins.

However, some strains cause cramps and diarrhea in humans. One particular strain, O157:H7, produces a powerful toxin that can cause severe illness. Health organizations across the world have selected E.coli as the most reliable indicator for the bacteriological quality of drinking water.

"The presence of E.coli in water is a strong indication of recent sewage or animal waste contamination. Sewage may contain many other types of disease-causing organisms." Saskatchewan Health Authority. (2022). *Drinking Water Quality Analysis*. Retrieved from the Saskatchewan Health Authority Website: [Drinking Water Quality Analysis | SaskHealthAuthority](#)

E. coli is not reported when total coliform are not detected. The E. coli limit set by WSA for drinking water is a MAC of 0 cts/100 mL.

Chlorine

Chlorine is an oxidizing agent that is commonly used as a disinfectant. When chlorine is added to water, it reacts to form two disinfectants known as "free residual chlorine" and "combined residual chlorine." WSA has placed a limit of not less than 0.2 mg/L of free residual chlorine in the water entering the distribution system from the water treatment plants. Additionally, a minimum of 0.10 mg/L of free residual chlorine or 0.50 mg/L of total residual chlorine (free plus combined) must be maintained continuously throughout the distribution system.

As per the permit to operate, the City must test free residual chlorine in the water entering the distribution system continuously or at least once per hour. The WTPs use on-line analytical instruments to monitor the free chlorine. Additionally, Operators sample water and test for free and total chlorine at least once daily at WTP #1 and hourly at FEH WTP while the plant is in operation. These tests are used to confirm that the online instruments are operating properly.

Turbidity

Turbidity is an assessment of water clarity and a measure of suspended inorganic and organic particles in the water. Turbidity can be caused by sediment, particles of dirt, clay, silt, air bubbles, vegetation, plankton, and other microscopic organisms suspended in the water. Turbid water may protect microorganisms from disinfection or prevent the removal of naturally occurring particles that the treatment process wants to control or eliminate.

As per the permit to operate, the limit for turbidity leaving WTP #1 is to be less than 1.0 NTU in 95% of readings and the limit leaving the filters at FEH WTP is to be less than 0.3 NTU in 95% of readings and never more than 1.0 NTU off each filter. WSA does not provide a limit for the turbidity within the distribution system. However, the City has implemented practices to maintain turbidity levels below 5.0 NTU in the distribution system.

Iron

Iron is an inorganic element and one of the most abundant metals in the earth's crust. Small quantities of iron are naturally found in many groundwater sources. An AO of less than 0.3 mg/L is used to minimize iron staining of laundry and plumbing fixtures, and to reduce undesirable tastes in consumption.

Manganese

Manganese is a naturally occurring inorganic element from the erosion and weathering of rocks and minerals. Water naturally contains small amounts of manganese; the

guideline limit is based on taste and staining of laundry and plumbing fixtures. The AO for manganese in drinking water is less than 0.05 mg/L.

Additional Testing

Additional water quality parameters are sampled for and analyzed as set out in the Permit to Operate a Waterworks, as directed by WSA, or at the discretion of the City of North Battleford.

General Chemical

A general water quality analysis is done semi-annually on the treated water from WTP #1 and quarterly from FEH WTP. Some of the parameters tested have guideline limits while others do not. The presence of some parameters may interfere with the removal of health-related parameters (such as bacteria). They may affect the treatment system's effectiveness and may be indicators of the overall water quality.

Chemical Health

A chemical water quality analysis is done semi-annually on the treated water from WTP #1 and quarterly from FEH WTP. Some of the parameters tested have guideline limits while others do not. Trace elements harmful to human health that may be present in North Battleford's water are monitored. These elements can be naturally occurring or the result of leaching, runoff, or spills.

Trihalomethanes/Haloacetic Acids

Trihalomethanes (THMs) and Haloacetic Acids (HAAs) are organic compounds formed in drinking water as a by-product of chlorine disinfection. THMs and HAAs may be linked to cancer or other health problems. The MAC for total THMs is 100 µg/L (0.1 mg/L) and total HAAs is 80 µg/L (0.08 mg/L) based on an annual average of quarterly tests. No samples were collected in 2025 with the next samples scheduled for collection in 2027.

Pesticides

The City of North Battleford tests for pesticides in the treated water once every two years. Pesticides samples were taken in 2025. Pesticides can enter source water (usually surface water) as a result of leaching and runoff from agricultural or other uses. Limits on pesticide concentrations are health-based and subject to a MAC.

Organics

The City of North Battleford tests for organics in the treated water once every two years. Organics samples were taken in 2025. Organics, usually petroleum products, can enter source water through a variety of means. Limits on organics are mainly health-based and subject to a MAC. A few are subject to an AO.

Cryptosporidium and Giardia

Cryptosporidium and Giardia are pathogens commonly found in surface water. They are associated with gastrointestinal upset. They can cause nausea, vomiting and diarrhoea. Cryptosporidium oocysts and Giardia cysts are found in human and animal wastes, which sometimes wash into rivers and lakes.

The minimum treatment process goal is a 3 log (99.9%) reduction or inactivation of Cryptosporidium oocysts and Giardia cysts. The combination of physical removal (filtration) and the use of an ultraviolet treatment system allows FEH WTP to reach this requirement. Cryptosporidium and Giardia are tested semi-annually from raw water entering FEH WTP and under upset conditions for treated water at FEH WTP.

Microcystin

Microcystins are tested in the treated water at FEH WTP by the City of North Battleford once a month from June to October (a total of 5 samples are collected). Microcystins are toxins produced by blue-green algae. Blue-green algae are commonly found in surface water when conditions are favourable for growth and are present in the formation of algal blooms. The toxins are released when the algae die and may continue to be present in the water for weeks to months. Microcystins are liver toxins and may be a skin, eye and throat irritant.

Blue-green algal blooms can occur with adequate levels of phosphorous and nitrogen, a temperature range of 5 to 30 degrees Celsius, and in pH between 6 and 9. Most blooms will occur in late summer and early fall. The MAC for total microcystins is 1.5 µg/L.

Wastewater Discharged to Environment

In 2022 the City's Permit to Operate was updated and now includes sampling requirements for Wastewater Discharged to Environment (WDE) for the protection of the receiving fresh water environment. All water that is released to the environment from the water treatment plants (filter backwash, plant maintenance/repairs) and does not enter the distribution system is considered wastewater and needs to be sampled for the following parameters:

- Chlorine Residual (on-site testing) – Daily
- Aluminum (off-site laboratory testing) – Monthly
- pH (on-site testing) – Weekly
- Dissolved Oxygen (on-site testing) – Weekly
- Total Suspended Solids (on-site testing) – Monthly
- Acute Lethality (off-site laboratory testing) – Annually

Results

The summary of the sampling results at each of the WTPs, as well as the results for the tested parameters, are discussed below. All samples collected (excluding select WDE on-site testing) were submitted to accredited laboratories for appropriate analysis. Refer to **Appendix B** for detailed tables showing the sampling data.

WTP #1 Summary

The treated water leaving WTP #1 was tested for five parameters (turbidity, free chlorine, total chlorine, iron, and manganese) daily and met the guidelines set out by WSA.

The average monthly turbidity readings were within the limits of the Permit to Operate and ranged from 0.07 NTU to 0.18 NTU. The highest average monthly reading of 0.18 NTU is below the limit of 1.0 NTU set by WSA.

The monthly free chlorine readings for water leaving the plant from the on-line analyzer ranged from 1.18 to 1.65 mg/L. The low limit set by WSA is not less than 0.2 mg/L for the water leaving the plant.

Iron concentrations ranged from 0.01 mg/L to 0.02 mg/L.

Manganese concentrations ranged from 0.01 mg/L to 0.09 mg/L.

A summary of the results for WTP #1 can be found in Appendix B, Table 1.

FEH WTP Summary

The treated water leaving FEH WTP was tested daily for turbidity and free chlorine and met the guidelines set by WSA. Turbidity was tested leaving the filters and clear well, while the free chlorine was tested leaving the clear well.

The turbidity leaving the four filters:

Filter A ranged from 0.00 – 0.34 NTU,
Filter B ranged from 0.01 – 0.56 NTU,
Filter C ranged from 0.01 – 0.18 NTU, and
Filter D ranged from 0.01 – 0.43 NTU.

The highest turbidity readings recorded from the filters was 0.56 NTU (March) while the lowest reading was 0.00 NTU. (June/October).

The monthly average free chlorine concentrations recorded entering the distribution system ranged from 0.50 mg/L to 1.35 mg/L. The highest chlorine concentration recorded was 2.00 mg/L (May) while the lowest was 0.41 mg/L (December).

A summary of the results for FEH WTP can be found in Appendix B, Table 2.

Distribution System Routine and 'Other' Bacteria Sampling

In 2025, a total of 270 samples were submitted for analysis as part of the routine monitoring required by WSA. None of the routine samples tested positive for coliforms/E.coli. Free and total chlorine residuals and turbidity were measured in each routine sample. All samples were within applicable guidelines.

A total of 89 'other' samples were submitted for testing. None of the 'other' samples tested positive for coliforms/E.coli. Free and total chlorine residuals and turbidity were measured in each sample. The results are shown in Appendix B, Table 3.

General Chemical

Two samples of the treated water from WTP#1 and four from FEH WTP were submitted for analysis for General Chemical analysis in 2025. The parameters tested met all aesthetic and health objectives. The results can be found in Appendix B, Table 4.

Chemical Health

Two samples of the treated water from WTP#1 and four from FEH WTP were submitted for Chemical Health. in 2025. The parameters tested were either within guidelines or below detection limits. The results can be found in Appendix B, Table 5..

Cyanide and Mercury

One sample of treated water from each plant was submitted for Cyanide and Mercury in 2025. The parameters tested were either within guidelines or below detection limits. The results can be found in Appendix B, Table 6.

Cryptosporidium and Giardia

Two samples of the raw water from FEH WTP were submitted for Cryptosporidium and Giardia analysis in February and October of 2025. Cryptosporidium oocysts were 0.00 oocysts/100 L (February and October). Giardia cysts were 37 cysts/100 L (February) and 0 cysts/100 L (October). There are no limits applied to Cryptosporidium and Giardia sampling. The results can be found in Appendix B, Table 7.

Pesticides

One sample of the treated water from WTP #1 and FEH WTP was submitted for Pesticides analysis in 2025. All tested parameters were below detection limits. The results are shown in Appendix B, Table 8.

Organics

One sample of the treated water from WTP #1 and FEH WTP was submitted for Organics analysis in 2025. All tested parameters were below detection limits. The results are shown in Appendix B, Table 9.

Wastewater Discharged to Environment

Chlorine Residual

The limit applied to Chlorine Residual is to be non-detectable. The Chlorine Residual from WTP #1 ranged from -0.126 mg/L to 0.027 mg/L and from FEH WTP ranged from -0.79 mg/L to 0.02 mg/L. This range falls within the expected error of a zero reading and is considered non-detectable. The results can be found in Appendix B, Table 10.

Aluminum

Aluminum does not have a limit applied. Aluminum results from WTP #1 ranged from 0.001 mg/L to 0.0340 mg/L and from FEH WTP ranged from 0.023 mg/L to 2.83 mg/L. The results can be found in Appendix B, Table 11.

pH

pH does not have a limit applied. pH results from WTP #1 ranged from 6.62 pH to 8.110 pH and from FEH WTP ranged from 6.73 pH to 9.08 pH. The results can be found in Appendix B, Table 12.

Dissolved Oxygen

Dissolved Oxygen does not have a limit applied. Dissolved Oxygen results from WTP #1 ranged from 3.54 mg/L to 10.79 mg/L and from FEH WTP ranged from 7.60 mg/L to 12.42 mg/L. The results can be found in Appendix B, Table 13.

Total Suspended Solids (TSS)

The limit applied to TSS Shall be Determined by the Downstream Use and Impact Study. TSS results from WTP #1 ranged from 0.00 mg/L to 38.00 mg/L and from FEH WTP ranged from 0.00 mg/L to 3.50 mg/L. The results can be found in Appendix B, Table 14.

Acute Lethality

The Limit applied to Acute Lethality Shall be Non-Lethal to Greater than 50% of test organisms at 100% effluent concentration. On November 4, 2026 both treatment plants were sampled, WTP #1 had 0% survival rate at 100% concentration and FEH WTP had 100% survival rate at 100% concentration. WTP #1 was re-sampled on December 9, 2025, the results were 100% survival rate at 100%. The results can be found in Appendix B, Table 15.

Water Production

In 2025, 1.73 million m³ of potable water was produced by the two Water Treatment Plants. WTP #1 produced 0.88 million m³, while FEH WTP produced 0.85 million m³ of potable water. Prior to 2024 FEH WTP was considered a peaking plant and was operated as needed. Due to low wellfield water production in the WTP #1, WTP #1 is now considered a peaking plant and FEH WTP is operated as the primary plant during periods of high water demand.

The water production results are shown in Appendix C. Combined, the monthly water production by both water treatment plants ranged from a low of 115,047 m³ (February) to a high of 183,658 m³ (May). The average daily production was 4,732 m³. The lowest average daily production was 3,957 m³ in December, and the peak average daily production was 5,924 m³ in May.

Conclusion

A total of 270 water distribution system bacteria samples were submitted as part of the routine monitoring of the distribution system. None of the routine bacteria samples tested positive for total coliforms and they were all within the recommended chlorine residual guidelines set by the WSA.

The online turbidity analyzers for Water Treatment Plant #1 ranged from 0.07 NTU to 0.18 NTU monthly average, meeting the guideline of less than 1.0 NTU for 95% of readings.

The turbidity for the F.E. Holliday Treatment Plant filters ranged from 0.00 to 0.34 NTU for Filter A, 0.01 to 0.56 NTU for Filter B, 0.01 to 0.18 NTU for Filter C, and 0.01 to 0.43 NTU for Filter D. All Filters were below the NTU guidelines of less than 0.3 NTU for 95% of readings and at no time exceeded the Absolute Maximum of 1.0 NTU.

Monthly free chlorine readings were above the minimum guideline of 0.2 mg/L entering the distribution system. The monthly readings ranged from 1.18 mg/L to 1.65 mg/L at Water Treatment Plant #1 and 0.50 mg/L to 1.35 mg/L at the F.E Holliday Treatment Plant.

The highest iron reading recorded was 0.02 mg/L at Water Treatment Plant #1 which was below the aesthetic guidelines of 0.3 mg/L.

The highest manganese reading recorded was 0.09 mg/L at Water Treatment Plant #1 which is above the aesthetic guidelines of 0.05 mg/L. The average monthly readings were 0.01 mg/L for each month.

In 2025 the City produced 1.73 million m³ compared to 1.67 million m³ in 2024.

The City of North Battleford water treatment plants provided potable water that met the Water Security Agency guidelines.

Acknowledgement

The City Operations Department of the City of North Battleford prepared this report. The dedication and commitment of civic staff in providing safe water is acknowledged.

Also acknowledged is the ongoing assistance of WSA.


For more information, please contact:

City of North Battleford

City Operations Department
Box 460
North Battleford, SK
S9A 2Y6
Phone: (306) 445-1700

*City of North Battleford
Drinking Water Quality
2025 Report
Appendix A: Map of Sampling Zones*

CNB NEIGHBORHOODS



- Neighborhoods**
1. Killdeer Park
 2. Fairview Heights
 3. McIntosh Park
 4. Centennial Park
 5. Maher Park
 6. Kinsmen Park
 7. Sapp Valley
 8. College Heights
 9. Downtown
 10. Paciwinn
 11. Deanscroft
 12. Riverview
 13. Yellow Sky
 14. Parsons Industrial Park

*City of North Battleford
Drinking Water Quality
2025 Report
Appendix B: Results Tables*

WTP #1 Summary									
Month	Train		CHLORINE			TURBIDITY		IRON mg/L	MANGANESE mg/L
			Free (SCADA) mg/L	Free (Lab) mg/L	Total mg/L	NTU (SCADA)	NTU (Lab)		
January	A	Average	1.65	1.33	1.58	0.09	0.12	0.02	0.01
		Max	2.21	1.74	2.01	0.15	0.17	0.04	0.03
		Min	1.32	1.07	1.29	0.05	0.09	0.00	0.00
	B	Average	1.42	1.39	1.66	0.08	0.12	0.02	0.01
		Max	2.00	1.97	2.46	0.14	0.20	0.04	0.03
		Min	1.14	1.14	1.35	0.03	0.08	0.00	0.00
February	A	Average	1.53	1.36	1.61	0.08	0.11	0.02	0.01
		Max	2.16	1.64	1.97	0.14	0.20	0.05	0.02
		Min	1.04	1.00	1.19	0.04	0.01	0.00	0.01
	B	Average	1.50	1.44	1.71	0.08	0.10	0.02	0.01
		Max	1.82	1.78	2.11	0.14	0.17	0.04	0.02
		Min	1.22	1.14	1.32	0.04	0.06	0.00	0.01
March	A	Average	1.38	1.34	1.59	0.05	0.08	0.01	0.01
		Max	1.88	1.68	2.12	0.09	0.13	0.04	0.02
		Min	1.02	1.04	1.28	0.04	0.06	0.00	0.00
	B	Average	1.46	1.44	1.71	0.05	0.08	0.01	0.01
		Max	1.89	1.89	2.16	0.10	0.12	0.04	0.02
		Min	1.15	1.17	1.37	0.03	0.01	0.00	0.00
April	A	Average	1.39	1.34	1.74	0.05	0.08	0.01	0.01
		Max	2.17	2.00	2.54	0.08	0.13	0.04	0.09
		Min	1.01	0.93	1.26	0.03	0.05	0.00	0.00
	B	Average	1.40	1.36	1.79	0.07	0.10	0.01	0.01
		Max	2.04	1.87	2.68	0.25	0.36	0.04	0.02
		Min	1.08	1.02	1.36	0.04	0.06	0.00	0.00
May	A	Average	1.43	1.37	1.90	0.04	0.09	0.01	0.01
		Max	2.27	2.17	2.94	0.06	0.11	0.04	0.02
		Min	0.92	0.84	1.37	0.02	0.06	0.00	0.00
	B	Average	1.49	1.50	2.08	0.18	0.26	0.02	0.01
		Max	3.09	3.24	4.35	0.48	0.67	0.05	0.02
		Min	0.86	0.82	1.41	0.12	0.18	0.00	0.01
June	A	Average	1.40	1.35	1.80	0.04	0.09	0.01	0.01
		Max	1.89	1.78	3.12	0.05	0.11	0.03	0.02
		Min	0.90	0.88	1.18	0.03	0.01	0.00	0.00
	B	Average	1.32	1.35	1.83	0.05	0.10	0.02	0.01
		Max	1.64	1.65	2.11	0.23	0.30	0.04	0.02
		Min	0.94	0.95	1.37	0.03	0.01	0.00	0.00

WTP #1 Summary Continued									
Month	Train		CHLORINE			TURBIDITY		IRON mg/L	MANGANESE mg/L
			Free (Lab) mg/L	Free (SCADA) mg/L	Total mg/L	NTU (Lab)	NTU (SCADA)		
July	A	Average	1.34	1.34	1.68	0.06	0.10	0.02	0.01
		Max	1.57	1.59	2.02	0.10	0.12	0.04	0.02
		Min	1.17	1.14	1.44	0.03	0.09	0.00	0.00
	B	Average	1.29	1.34	1.76	0.04	0.10	0.02	0.01
		Max	1.72	1.72	2.46	0.06	0.12	0.04	0.02
		Min	1.04	1.11	1.48	0.03	0.08	0.00	0.01
August	A	Average	1.44	1.41	1.71	0.03	0.09	0.02	0.01
		Max	1.75	1.74	2.07	0.05	0.12	0.06	0.02
		Min	1.14	1.14	1.37	0.03	0.01	0.00	0.00
	B	Average	1.31	1.34	1.70	0.04	0.10	0.02	0.01
		Max	1.53	1.60	1.95	0.06	0.14	0.06	0.02
		Min	1.08	1.09	1.37	0.03	0.01	0.00	0.00
September	A	Average	1.24	1.23	1.58	0.04	0.10	0.01	0.01
		Max	1.55	1.50	1.92	0.06	0.13	0.05	0.01
		Min	1.08	1.04	1.38	0.03	0.07	0.00	0.00
	B	Average	1.13	1.20	1.58	0.04	0.10	0.01	0.01
		Max	1.34	1.43	1.85	0.06	0.13	0.03	0.02
		Min	1.01	1.09	1.34	0.03	0.07	0.00	0.00
October	A	Average	1.22	1.18	1.64	0.07	0.12	0.01	0.01
		Max	1.54	1.48	2.07	0.10	0.20	0.04	0.01
		Min	0.82	0.81	1.21	0.04	0.07	0.00	0.00
	B	Average	1.27	1.27	1.77	0.05	0.12	0.01	0.01
		Max	1.90	1.86	2.86	0.07	0.19	0.04	0.02
		Min	0.80	0.84	1.23	0.04	0.06	0.00	0.00
November	A	Average	1.32	1.28	1.66	0.03	0.09	0.01	0.01
		Max	1.63	1.59	2.07	0.12	0.14	0.04	0.09
		Min	0.85	0.87	1.15	0.02	0.06	0.00	0.00
	B	Average	1.27	1.30	1.69	0.04	0.08	0.01	0.01
		Max	1.65	1.73	2.16	0.06	0.13	0.04	0.01
		Min	0.96	0.98	1.30	0.02	0.01	0.00	0.00
December	A	Average	1.34	1.33	1.63	0.02	0.07	0.01	0.01
		Max	2.05	2.02	2.50	0.03	0.12	0.04	0.02
		Min	1.10	1.11	1.29	0.00	0.05	0.00	0.00
	B	Average	1.29	1.32	1.66	0.02	0.07	0.01	0.01
		Max	1.84	1.87	2.18	0.04	0.11	0.04	0.02
		Min	0.93	0.98	1.30	0.02	0.05	0.00	0.00

FEH WTP Summary										
Date	Raw Water		Filter Effluent - Turbidities (NTU)				Clearwell A		Clearwell B	
	RATE (m3/hr)	TURBIDITY (NTU)	Filter A TURB	Filter B TURB	Filter C TURB	Filter D TURB	Turb (NTU)	Free Cl	Turb (NTU)	Free Cl
January										
Average	265	4.45	0.04	0.05	0.02	0.03	0.09	1.15	0.07	1.35
Max	340	6.47	0.09	0.13	0.05	0.06	0.17	1.73	0.14	1.66
Min	118	3.28	0.02	0.03	0.02	0.02	0.02	0.94	0.02	1.15
February										
Average	269	4.95	0.04	0.03	0.03	0.04	0.04	1.13	0.04	1.31
Max	329	9.57	0.10	0.08	0.08	0.28	0.07	1.45	0.09	1.52
Min	178	3.05	0.02	0.02	0.02	0.03	0.03	0.87	0.03	1.16
March										
Average	292	4.05	0.05	0.04	0.03	0.04	0.06	1.09	0.06	1.32
Max	351	5.75	0.14	0.56	0.11	0.14	0.13	1.69	0.11	1.58
Min	184	3.10	0.03	0.02	0.02	0.02	0.04	0.82	0.03	1.05
April										
Average	312	51.15	0.04	0.04	0.03	0.04	0.08	1.05	0.06	1.21
Max	351	187.00	0.21	0.20	0.10	0.43	0.20	1.30	0.11	1.51
Min	180	3.62	0.02	0.02	0.02	0.03	0.02	0.76	0.02	0.92
May										
Average	299	36.27	0.05	0.07	0.03	0.04	0.04	1.25	0.04	1.24
Max	362	121.00	0.31	0.23	0.08	0.37	0.07	2.00	0.08	1.48
Min	132	7.85	0.03	0.02	0.02	0.03	-0.07	0.97	0.02	1.08
June										
Average	269	26.58	0.06	0.04	0.04	0.05	0.05	1.23	0.06	1.22
Max	356	82.40	0.30	0.16	0.10	0.13	0.08	1.36	0.11	1.38
Min	151	7.95	0.01	0.00	0.01	0.02	0.03	1.02	0.03	0.99
July										
Average	292	29.55	0.05	0.06	0.04	0.04	0.06	1.19	0.05	1.28
Max	347	101.00	0.34	0.33	0.12	0.09	0.09	1.41	0.10	1.45
Min	181	11.20	0.03	0.03	0.02	0.02	0.03	1.01	0.03	1.04
August										
Average	301	34.37	0.04	0.04	0.04	0.03	0.05	1.19	0.06	1.28
Max	349	100.00	0.30	0.15	0.18	0.146	0.10	1.37	0.11	1.42
Min	183	12.90	0.02	0.03	0.02	0.02	0.02	1.05	0.03	1.15
September										
Average	296	15.01	0.05	0.07	0.03	0.04	0.04	1.20	0.04	1.28
Max	352	24.80	0.13	0.15	0.08	0.08	0.07	1.33	0.08	1.41
Min	184	9.00	0.03	0.03	0.02	0.02	0.03	1.03	0.03	1.17
October										
Average	301	6.19	0.03	0.03	0.02	0.03	0.03	1.22	0.05	1.27
Max	356	9.11	0.16	0.10	0.07	0.21	0.05	1.38	0.08	1.41
Min	182	4.07	0.00	0.00	0.02	0.01	0.02	1.11	0.03	1.19

FEH WTP Summary Continued										
Date	Raw Water		Filter Effluent - Turbidities (NTU)				Clearwell A		Clearwell B	
	RATE (m3/hr)	TURBIDITY (NTU)	Filter A TURB	Filter B TURB	Filter C TURB	Filter D TURB	Turb (NTU)	Free Cl	Turb (NTU)	Free Cl
November										
Average	245	7.21	0.04	0.03	0.03	0.04	0.04	1.04	0.05	1.06
Max	354	10.80	0.10	0.08	0.05	0.11	0.07	1.33	0.07	1.32
Min	146	4.80	0.04	0.03	0.02	0.03	0.02	0.65	0.03	0.77
December										
Average	208	4.12	n/a	n/a	0.03	0.03	0.43	0.50	0.60	0.95
Max	276	5.07	n/a	n/a	0.04	0.05	1.21	1.02	1.04	1.29
Min	62	3.38	n/a	n/a	0.03	0.03	0.08	0.41	0.03	0.70

Note: FEH WTP was shut down for maintenance for most of the month of December.

**TABLE 3
ROUTINE AND OTHER SAMPLING**

Routine and Other Sampling						
LOCATION	SAMPLES	BACTERIOLOGICAL # of Positive Samples			CHLORINE # of Samples Below Guidelines	TURBIDITY
	# of Samples Collected	>200 Background Colonies	Total Coliform (MPN/100 mL)	E. Coli (MPN/100 mL)	Total < 0.5 mg/L Free < 0.1 mg/L	Average (NTU)
Killdeer Park	18	0	0	0	0	0.22
Fairview Heights	44	0	0	0	0	0.26
McIntosh Park	43	0	0	0	0	0.22
Downtown	24	0	0	0	0	0.26
Yellow Sky	92	0	0	0	0	0.19
Riverview	27	0	0	0	0	0.24
Parsons Industrial Park	22	0	0	0	0	0.18
Other ¹	89	0	0	0	0	0.59
Total Routine Samples	270	0	0	0	0	0.22
Total Other Samples²	89	0	0	0	0	0.59

¹ These samples are not part of the routine sampling

Table 4 - General Chemical for WTP #1				
Parameter	Units	13-Feb	14-Aug	AO
		Results	Results	
Bicarbonate	mg/L	227	222	
Calcium	mg/L	72	69	
Carbonate	mg/L	<1	<1	
Chloride	mg/L	18	18	250
Hydroxide	mg/L	<1	<1	
Magnesium	mg/L	24	23	200
pH	pH Units	7.77	7.86	6.5-9.0
Potassium	mg/L	2.2	2.2	
Sodium	mg/L	30	26	300
E.C.	uS/cm	654	655	
Sulphate	mg/L	120	120	500
Sum of Ions	mg/L	494	480	
Total Alkalinity	mg/L	186	182	500
Total Hardness	mg/L	278	267	800
Nitrate	mg/L	0.90	<0.04	
Fluoride	mg/L	0.13	0.13	1.5
TDS	mg/L	442	420	1500

Table 4 - General Chemical for FEH WTP#2						
Parameter	Units	13-Feb	6-May	14-Aug	5-Nov	AO
		Results	Results	Results	Results	
Bicarbonate	mg/L	150	151	137	146	
Calcium	mg/L	51	50	49	45	
Carbonate	mg/L	<1	<1	<1	<1	
Chloride	mg/L	24	26	26	16	250
Hydroxide	mg/L	<1	<1	<1	<1	
Magnesium	mg/L	16	15	14	14	200
pH	pH Units	7.62	7.59	7.29	7.98	6.5-9.0
Potassium	mg/L	1.4	3	1.4	1.2	
Sodium	mg/L	14	15	5.9	8	300
E.C.	uS/cm	453	461	399	394	
Sulfate	mg/L	64	66	47	52	500
Sum of Ions	mg/L	494	326	282	284	
Total Alkalinity	mg/L	123	124	112	120	500
Total Hardness	mg/L	193	186	180	170	800
Nitrate	mg/L	3.40	<0.04	1.90	1.40	45*
Fluoride	mg/L	0.11	0.1	0.1	0.1	1.5
TDS	mg/L	286	287	244	231	1500

*MAC based on Nitrate as NO₃

Table 6 - Chemical Health for WTP #1						
Parameter	Units	WTP#1	WTP#1	MAC (mg/L)	iMAC (mg/L)	AO (mg/L)
		13-Feb	14-Aug			
Aluminum	mg/L	0.0013	0.0012			
Arsenic	ug/L	0.1	0.1	0.01	0.025	
Barium	mg/L	0.12	0.13	1		
Boron	mg/L	0.03	0.03		5	
Cadmium	mg/L	<0.00001	<0.00001	0.005		
Chromium	mg/L	<0.0005	<0.0005	0.05		
Copper	mg/L	0.0004	<0.0002			
Iron	mg/L	0.15	0.0034			0.3
Lead	mg/L	<0.0001	<0.0001	0.01		
Manganese	mg/L	0.0043	0.006			0.05
Selenium	mg/L	<0.0001	<0.0001	0.01		
Uranium	ug/L	0.2	0.1	0.02		
Zinc	mg/L	<0.0005	0.0005			5

Table 6 - Chemical Health for FEH								
Parameter	Units	WTP#2	WTP#2	WTP#2	WTP#2	MAC (mg/L)	iMAC (mg/L)	AO (mg/L)
		13-Feb	6-May	14-Aug	5-Nov			
Aluminum	mg/L	0.021	0.038	0.042	0.022			
Arsenic	ug/L	<0.1	0.2	0.1	<0.1	0.01	0.025	
Barium	mg/L	0.065	0.065	0.064	0.055	1		
Boron	mg/L	0.01	0.02	0.01	0.01		5	
Cadmium	mg/L	0.00001	0.00001	0.00001	0.00001	0.005		
Chromium	mg/L	<0.0005	<0.0005	<0.0005	<0.0005	0.05		
Copper	mg/L	0.0008	0.0011	0.0007	0.0006			
Iron	mg/L	0.0021	0.0006	0.0014	0.0006			0.3
Lead	mg/L	<0.0001	<0.0001	<0.0001	<0.0001	0.01		
Manganese	mg/L	0.0049	0.0025	0.0042	0.002			0.05
Selenium	mg/L	0.0002	0.0003	0.0003	0.0002	0.01		
Uranium	ug/L	0.2	0.2	<0.1	0.1	0.02		
Zinc	mg/L	0.0015	0.0008	<0.0005	0.0007			5

Table 6 - Cyanide and Mercury for WTP #1 and FEH				
Parameter	Units	WTP#1	WTP#2	MAC (mg/L)
		11-Jun	11-Jun	
Cyanide	mg/L	<0.001	<0.001	0.2
Mercury	mg/L	<0.001	<0.001	0.001

Crypto and Giardia			
Parameter	Units	Results	Results
		26-Feb-25	14-Oct-25
Volume Filtered	L	40	40
Giardia cysts	cysts/100L	37	0
Cryptosporidium oocysts	oocysts/100L	0	0

Table 8 - Pesticides					
Parameter	Units	WTP#1	WTP#2	MAC (mg/L)	iMAC (mg/L)
		12-Aug-25	12-Aug-25		
Atrazine	µg/L	<0.2	<0.2		0.005
Bromoxynil(Buctril)	µg/L	<2	<2		0.005
Carbofuran	µg/L	<0.2	<0.2	0.09	
Chlorpyrifos(Lorsban)	µg/L	<0.2	<0.2	0.09	
Dicamba(Banvel)	µg/L	<1	<1	0.12	
2,4 D	µg/L	<1	<1		0.1
Diclofop-methyl(HoeGrass)	µg/L	<1	<1	0.009	
Dimethoate(Cygon)	µg/L	<5	<5		0.02
Malathion	µg/L	<0.2	<0.2	0.19	
MCPA	µg/L	<1	<1	0.1	
Pentachlorophenol(PCP)	µg/L	<2	<2	0.06	
Picloram(Tordon)	µg/L	<1	<1		0.19
Trifluralin(Treflan)	µg/L	<0.2	<0.2		0.045

Table 9 - Organics						
Parameter	Units	WTP#1	WTP#2	MAC (mg/L)	iMAC (mg/L)	AO (mg/L)
		12-Aug	12-Aug			
BTEX						
Benzene	µg/L	<0.5	<0.5	0.005		
Toluene	µg/L	<0.5	<0.5	0.060		0.024
Ethylbenzene	µg/L	<0.5	<0.5	0.140		0.0016
Xylenes	µg/L	<0.5	<0.5	0.090		
Organochlorides						
Benzo(a)pyrene	µg/L	<0.01	<0.01	0.00001		
Carbon tetrachloride	µg/L	<2	<2	0.005		
Dichlorobenzene, 1,2	µg/L	<0.5	<0.5	0.2		
Dichlorobenzene, 1,4	µg/L	<0.5	<0.5	0.005		
Dichloroethane, 1,2	µg/L	<0.5	<0.5		0.005	
Dichloroethylene, 1,1	µg/L	<0.5	<0.5	0.014		
Dichloromethane	µg/L	<0.5	<0.5	0.05		
Dichlorophenol, 2,4	µg/L	<0.2	<0.2	0.9		
Perfluorooctane Sulfonate (PFOS)	µg/L	<0.0020	<0.0020	<0.0020		
Perfluorooctanoic Acid (PFOA)	µg/L	<0.0020	<0.0020	<0.0020		
Monochlorobenzene	µg/L	<0.5	<0.5	0.08		
Tetrachlorophenol, 2,3,4,6	µg/L	<1	<1	0.1		
Trichloroethylene	µg/L	<0.5	<0.5	0.05		
Trichlorophenol, 2,4,6	µg/L	<2	<2	0.005		
Vinyl Chloride	µg/L	<0.5	<0.5	0.002		

Waste to Discharge - Chlorine Residual (mg/L)			
Month		WTP #1	FEH WTP
January	Average	-0.017	-0.004
	Min	-0.126	-0.020
	Max	0.020	0.010
February	Average	0.005	-0.003
	Min	-0.018	-0.020
	Max	0.027	0.020
March	Average	0.004	-0.003
	Min	0.000	-0.020
	Max	0.020	0.010
April	Average	0.001	-0.028
	Min	0.000	-0.790
	Max	0.010	0.020
May	Average	0.002	0.001
	Min	0.000	0.000
	Max	0.010	0.010
June	Average	0.002	0.000
	Min	0.000	0.000
	Max	0.010	0.000
July	Average	0.003	0.000
	Min	0.000	0.000
	Max	0.010	0.000
August	Average	0.003	0.000
	Min	0.000	0.000
	Max	0.010	0.000
September	Average	0.002	0.000
	Min	0.000	0.000
	Max	0.010	0.000
October	Average	0.001	0.000
	Min	0.000	0.000
	Max	0.010	0.010
November	Average	0.003	0.000
	Min	0.000	0.000
	Max	0.020	0.000
December	Average	0.000	0.000
	Min	0.000	0.000
	Max	0.010	0.000

Waste to Discharge - Aluminum			
Date	Units	Results	
		WTP#1	FEH WTP
15-Jan-25	mg/L	0.008	0.023
19-Feb-25	mg/L	0.003	0.065
20-Mar-25	mg/L	0.002	2.830
16-Apr-25	mg/L	0.034	0.028
21-May-25	mg/L	0.002	0.06
18-Jun-25	mg/L	0.003	0.10
16-Jul-25	mg/L	<0.0005	0.29
20-Aug-25	mg/L	0.002	0.04
17-Sep-25	mg/L	0.002	0.06
15-Oct-25	mg/L	0.003	0.03
19-Nov-25	mg/L	0.001	0.29
17-Dec-25	mg/L	<0.003	---
27-Dec-25	mg/L	---	0.30

Waste to Discharge - pH			
Month		WTP #1	FEH WTP
January	Average	7.190	7.51
	Min	7.100	7.05
	Max	7.280	7.74
February	Average	7.550	7.42
	Min	7.000	7.24
	Max	8.110	7.56
March	Average	7.650	7.21
	Min	7.110	6.97
	Max	7.870	7.60
April	Average	7.472	6.91
	Min	7.210	6.73
	Max	8.070	7.37
May	Average	7.465	7.05
	Min	7.270	6.80
	Max	7.760	7.40
June	Average	7.160	7.10
	Min	7.000	6.93
	Max	7.400	7.58
July	Average	7.374	7.13
	Min	7.120	6.88
	Max	7.730	7.76
August	Average	7.430	8.07
	Min	7.020	7.49
	Max	7.960	8.53
September	Average	7.546	8.12
	Min	7.260	7.58
	Max	8.100	9.08
October	Average	7.784	7.69
	Min	7.350	7.53
	Max	8.020	7.91
November	Average	7.493	7.77
	Min	6.620	7.66
	Max	7.870	7.88
December	Average	7.264	7.55
	Min	7.220	7.52
	Max	7.320	7.57

Waste to Discharge - Dissolved Oxygen (mg/L)			
Month		WTP #1	FEH WTP
January	Average	9.28	11.59
	Min	7.04	10.57
	Max	10.55	12.42
February	Average	8.49	11.37
	Min	8.21	10.08
	Max	8.80	12.26
March	Average	8.82	11.24
	Min	8.42	10.34
	Max	9.76	11.79
April	Average	9.28	10.54
	Min	7.91	8.39
	Max	10.79	11.88
May	Average	9.03	9.08
	Min	7.76	8.63
	Max	10.22	9.92
June	Average	9.57	8.73
	Min	9.34	8.30
	Max	9.83	9.24
July	Average	9.18	7.93
	Min	7.73	7.60
	Max	9.81	8.23
August	Average	9.20	8.31
	Min	7.33	8.20
	Max	10.04	8.41
September	Average	9.56	8.22
	Min	8.68	7.74
	Max	9.85	8.61
October	Average	9.31	8.83
	Min	8.97	7.74
	Max	9.88	10.42
November	Average	9.69	10.95
	Min	9.42	9.91
	Max	9.99	11.98
December	Average	8.06	11.63
	Min	3.54	11.03
	Max	9.42	12.23

Waste to Discharge - TSS (mg/L)			
Date	Units	Results	
		WTP#1	FEH WTP
15-Jan-25	mg/L	38.00	0.25
19-Feb-25	mg/L	1.75	1.75
20-Mar-25	mg/L	2.50	0.00
16-Apr-25	mg/L	8.38	1.50
21-May-25	mg/L	0.00	0.13
18-Jun-25	mg/L	1.63	0.63
16-Jul-25	mg/L	1.38	0.63
20-Aug-25	mg/L	5.25	3.38
17-Sep-25	mg/L	0.00	3.50
6-Oct-25	mg/L	0.93	0.03
9-Nov-25	mg/L	0.00	0.29
17-Dec-25	mg/L	2.40	---

Waste to Discharge - Acute Lethality					
Parameter	Species	Unit	4-Nov		Limit
			WTP#1	FEH WTP	
Acute (96 hr LC ₅₀ - survival)	Trout	%	0	>100	>50

Resample - Waste to Discharge - Acute Lethality - WTP#1					
Parameter	Species	Unit	9-Dec		Limit
			WTP#1	FEH WTP	
Acute (96 hr LC ₅₀ - survival)	Trout	%	>100	N/A	>50

Note:

At WTP #1, the November 4, 2025 Acute Lethality had 0% survival rate at 100% concentration. WTP #1 was re-sampled on December 9, 2025 and had a 100% survival rate at 100% concentration.